

## FIRE SAFETY SCHEDULE

### ENVIRONMENTAL PLANNING AND ASSESSMENT REGULATION 2000 FIRE AND OTHER SAFETY MEASURES

Property Address: \_\_\_\_\_

Owners Name: \_\_\_\_\_

Owners Address: \_\_\_\_\_

Prepared by (Print Name): \_\_\_\_\_ Occupation (if not owner): \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Construction Certificate (CC / CDC) / Fire Safety Order No. – (office use only): \_\_\_\_\_

In order to ensure safety of persons in the building in the event of an outbreak of fire and pursuant to powers contained in Environmental Planning and Assessment Regulation 2000 the following fire and other safety measures are to be installed in the building. The fire and safety measures are to be capable of functioning at a standard of performance in accordance with the requirements of the Building Code of Australia or as indicated in the schedule. This Fire Safety Schedule specifies the fire safety measures (both existing and proposed) that should be implemented in the whole of the building premises.

Existing ✓	Proposed ✓	FIRE SAFETY MEASURES	PROPOSED Relevant Legislation (BCA 2011) / Standard (delete as required)	EXISTING Legislation/standard applicable at time of instalment (add as required)
<input type="checkbox"/>	<input type="checkbox"/>	Access panels, doors and hoppers to fire resisting shifts:	C3.13	
<input type="checkbox"/>	<input type="checkbox"/>	Automatic fail safe devices:	D2.21	
<input type="checkbox"/>	<input type="checkbox"/>	Automatic smoke detectors and alarm systems:	C3.5; C3.6; C3.7; C3.8; C3.11; Spec C3.4-3; D2.21; G4.8; E2.2; E4.9; Spec E2.2a; G3.8; Spec G3.8; AS 1670-2015 & AS 3786-1993/2014	
<input type="checkbox"/>	<input type="checkbox"/>	Automatic fire suppression systems:	Spec E1.5; CV3; AS 2118.1-1999/2017; AS 2118.4-2012 & AS 2118.6-2012	
<input type="checkbox"/>	<input type="checkbox"/>	Break glass panels:	Manufacturers specifications	
<input type="checkbox"/>	<input type="checkbox"/>	Carbon monoxide gas detection systems:	Manufacturers specifications	
<input type="checkbox"/>	<input type="checkbox"/>	Electric door strikes:	D2.21; D2.22 & Manufacturers specifications	
<input type="checkbox"/>	<input type="checkbox"/>	Electromagnetic devices:	C3.5; C3.6; C3.7; C3.8; C3.11; Spec 3.4-3; Spec D1.12-2 & Manufacturers specifications	
<input type="checkbox"/>	<input type="checkbox"/>	Emergency lifts:	C3.10; E3.6; H2.6; AS 1735.11 & AS 1735.12	
<input type="checkbox"/>	<input type="checkbox"/>	Emergency lighting:	A1.1; H3.15; E4.4; E4.8; AS/NZS 2293.1-2005 & AS/NZS 2293.3-2005	
<input type="checkbox"/>	<input type="checkbox"/>	Sound system and intercom system for emergency purposes : (Building occupant warning system)	E4.9; G3.8; Spec G3.8 & AS 1670.4-2015	
<input type="checkbox"/>	<input type="checkbox"/>	Exit signs:	E4.4; E4.8 & AS/NZS 2293.1-2005	
<input type="checkbox"/>	<input type="checkbox"/>	External wall wetting sprinklers::	C3.4 & D1.7	
<input type="checkbox"/>	<input type="checkbox"/>	Fire blankets:	E1.6 & AS 2444-2001	
<input type="checkbox"/>	<input type="checkbox"/>	Fire control centres and rooms:	E1.8 & Spec E1.8	
<input type="checkbox"/>	<input type="checkbox"/>	Fire dampers	C3.12; NSW H101 & AS 1668.1-1998	

Existing ✓	Proposed ✓	FIRE SAFETY MEASURES	PROPOSED Relevant Legislation (BCA 2011) / Standard (delete as required)	EXISTING Legislation/standard applicable at time of instalment (add as required)
<input type="checkbox"/>	<input type="checkbox"/>	Fire doors:	C2.5; C2.12; C2.13; C3.4; C3.5; C3.6; C3.7; C3.8; C3.10; C3.11; C3.13; Spec C3.4-2; D1.8; D2.8; Spec C3.4; Spec D1.12-2; Spec E1.8-7.8; G3.4; AS 1905.1- 2015 & AS 1735.2-2005	
<input type="checkbox"/>	<input type="checkbox"/>	Fire hydrant systems:	C2.12; E1.3 & AS 2419.1-2005	
<input type="checkbox"/>	<input type="checkbox"/>	Fire seals protecting openings in fire resisting components of the building:	C2.5; C3.15	
<input type="checkbox"/>	<input type="checkbox"/>	Fire shutters:	Spec C3.4 & AS 1905.2-2005	
<input type="checkbox"/>	<input type="checkbox"/>	Fire windows:	C3.4; C3.8; C3.11; D1.8 & Spec C3.4-5	
<input type="checkbox"/>	<input type="checkbox"/>	Pre-engineered fire protection systems (cooking equipment)	AS 3772-2008	
<input type="checkbox"/>	<input type="checkbox"/>	Hose reel systems:	E1.4 & AS 2441	
<input type="checkbox"/>	<input type="checkbox"/>	Lightweight construction:	C1.8; C2.5; C2.14; C3.4; C3.17; Spec C1.1-5.1; D2.4; D2.6; D2.8 & Spec C1.8	
<input type="checkbox"/>	<input type="checkbox"/>	Mechanical air handling systems:	E2.2, AS 1668.1-2015; C2.12; C3.15; Spec C2.5; D1.7; Spec E1.8; E4.12; Spec E2.26 & G3.8	
<input type="checkbox"/>	<input type="checkbox"/>	Perimeter vehicle access for emergency vehicles:	C2.3 & C2.4	
<input type="checkbox"/>	<input type="checkbox"/>	Portable fire extinguishers:	E1.6 & AS 2444-2001	
<input type="checkbox"/>	<input type="checkbox"/>	Air pressurization systems:	D1.7; D2.6; E2.2; Spec E1.8-8 & AS 1668.1	
<input type="checkbox"/>	<input type="checkbox"/>	Required exit doors (automatic)	C3.7; C3.8; C3.11 & Manufacturers specifications	
<input type="checkbox"/>	<input type="checkbox"/>	Safety curtains in proscenium openings:	Spec H1.3-6	
<input type="checkbox"/>	<input type="checkbox"/>	Self-closing fire hoppers:	C3.13 and G2.4	
<input type="checkbox"/>	<input type="checkbox"/>	Smoke detectors/alarms and heat detectors/alarms:	Spec E2.2a & AS 3786-1993/2017	
<input type="checkbox"/>	<input type="checkbox"/>	Smoke and heat vents:	Spec E2.2c; Spec G3.8 & AS 2665-2001	
<input type="checkbox"/>	<input type="checkbox"/>	Smoke exhaust systems:	C2.5; C2.12; C2.13; E2.2; Spec E2.2b; G3.8 & Spec G3.8	
<input type="checkbox"/>	<input type="checkbox"/>	Smoke dampers:	C2.5; Spec C2.5; C2.14 & AS 1851-2005	
<input type="checkbox"/>	<input type="checkbox"/>	Smoke doors:	C2.5; C2.14; Spec C3.4-3; D1.7; D1.9; D2.6 & G3.4	
<input type="checkbox"/>	<input type="checkbox"/>	Solid core doors:	C3.11	
<input type="checkbox"/>	<input type="checkbox"/>	Stand-by power systems:	E3.4; Spec G3.8-6 & Manufacturers specifications	
<input type="checkbox"/>	<input type="checkbox"/>	Wall wetting sprinkler and drencher systems:	AS 2008.1-1999/2017; Spec E1.5 & CV3	
<input type="checkbox"/>	<input type="checkbox"/>	Warning and operational signs	C3.6; D2.23; AS 2419.1-1994; Spec D1.12; AS 2441-1988; Spec E1.8-9; E3.3; E4.7 & Clause 183 of the Environmental Planning & Assessment Act-Regulation 2000	
<input type="checkbox"/>	<input type="checkbox"/>	Other:	(Fire Engineered Report/Alternate Solution, Evacuation Plan, Plan of Management etc..)	

Note: existing measures are to be certified to the legislation and standards applicable at the time of instalment